



Product Service

CERTIFICATE

No. Z2 108644 0001 Rev. 00

Holder of Certificate: **ECOSUN RENEWABLE ENERGY SOURCES LTD**
Voulgari 58
542 49 Thessaloniki
GREECE

Certification Mark:



Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 701262006401-00

Valid until: 2025-03-09

Date, 2020-06-12

(Zhulin Zhang)



CERTIFICATE

No. Z2 108644 0001 Rev. 00

Model(s): ES-72MONO xxx, xxx=340-405 in step of 5;
 ES-60MONO xxx, xxx=285-340 in step of 5;
 ES-144MONO xxx, xxx=390-415 in step of 5;
 ES-120MONO xxx, xxx=325-345 in step of 5;
 xxx is standing for rated output power at STC.

Parameters:

Construction:	Framed, with Junction box, Cable and connector.
Test Laboratory:	Yangzhou Opto-Electrical Products Testing Institute, No. 10 West Kaifa Road, Yangzhou 225009 Jiangsu, P. R. China.
Safety Class:	Class II
Max. system voltage:	1500V DC
Fire Safety Class:	Class C according to UL790

Tested according to:

- IEC 61215-1:2016
- IEC 61215-1-1:2016
- IEC 61215-2:2016
- IEC 61730-1:2016
- IEC 61730-2:2016

Production Facility(ies): 095833